



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

October 3, 2003
Subject: New Canada
Project No. STP-1005(100)X
PIN 10051.00
Bid Amendment No. 1

Dear Sir/Ms.:


Please make the following change to your Bid Package.

In the Plan sheets, on page 11 of 12 where it states "Aluminum Box Culvert Notes" Delete in its entirety note # 1, and replace with the new note # 1 "One 7010 mm span by 2946 mm rise Aluminum Structural Plate Box Culvert with full metal inverts is required. The manufacturer shall design the aluminum box, its plate thicknesses, and stiffeners in accordance with the manufacturer's published technical data, A.A.S.H.T.O. specifications, and the live load specified in the Plans."

Make this change in pen and ink.

Consider this change prior to submitting your bid on October 15, 2003.

Sincerely,


for Bruce R. Carter
Contracts Engineer



PRINTED ON RECYCLED PAPER